



17TH ADVANCED BEAM DYNAMICS WORKSHOP ON

FUTURE LIGHT SOURCES

APS Low-Energy Undulator Test Line Beam Diagnostics Development

G. Decker, A. Lumpkin, B.X. Yang, S. Kim, ANL

APRIL 6-9, 1999

ARGONNE NATIONAL LABORATORY, ARGONNE, IL U.S.A.

ADVANCED PHOTON SOURCE

APS Low-Energy Undulator Test Line Beam Diagnostics Development


Glenn Decker, Alex Lumpkin, Bingxin Yang, Suk Kim

Purpose

The purpose of this work is to develop particle beam diagnostics for ultra-short, ultra-bright particle beams. Specifically, a high-resolution single-pass beam position monitor (bpm) pickup electrode assembly has been designed, built, and tested, in addition to the development of electro-optic techniques using optical transition radiation. The long-range goal of this work is to support fourth-generation light source development.


ADVANCED PHOTON SOURCE

Geometry for BPM button geometry optimization



ADVANCED PHOTON SOURCE

Optimization of BPM Sum, Position Sensitivity with Geometry



$$V_{ps}(x_o, y_o) = \frac{V_p}{\pi} \left[\tan^{-1} \left\{ \frac{\sinh p(x - x_o)}{\cos py_o} \right\} + \tan^{-1} \left\{ \frac{\sinh p(x + x_o)}{\cos py_o} \right\} \right]_{x=x_1}^{x=x_2},$$


$$V_{py}(x_o, y_o) = \frac{V_p}{\pi} \left[\tan^{-1} \left\{ \frac{e^{2p(x-x_o)} + \cos 2py_o}{\sin 2py_o} \right\} - \tan^{-1} \left\{ \frac{e^{-2p(x+x_o)} + \cos 2py_o}{\sin 2py_o} \right\} \right]_{x_1}^{x_2},$$

$$V_{px}(x_o, y_o) = \frac{V_p}{\pi} \left[\tan^{-1} \left\{ \frac{\sinh p(x - x_o)}{\cos py_o} \right\} - \tan^{-1} \left\{ \frac{\sinh p(x + x_o)}{\cos py_o} \right\} \right]_{x_1}^{x_2}.$$


$p = \pi/2h$, h = half-gap height of the chamber

$x_1 = 0$, $x_2 = 2h$ for the optimized configuration


(a) Sum (Y_{ps})




(b) Vert (Y_{py})




Vert/Sum (Y_{py}/Y_{ps})




(c) Horz (Y_{px})



Horz/Sum (Y_{px}/Y_{ps})




3-D plots for (a) sum (Y_{ps}), (b) vertical (Y_{ps}) and normalized vertical (Y_{py}/Y_{ps}), and (c) horizontal (Y_{px}) and normalized horizontal (Y_{psx}/Y_{ps}) signals in the plane of $x_o = x_o/h$ and $y_o = y_o/h$ for the optimized configuration.



Standard S-Band BPM Stripline Pick-Up for Linac installed in PAR Bypass



Small Gap (4mm x 11mm) Button Type BPM




Small Gap (4mm x 11mm) Button Type BPM Installed in PAR Bypass

ADVANCED PHOTON SOURCE


Small Gap Beam Position Monitor Tests

Positron Accumulator Ring Bypass Transport Line






ADVANCED PHOTON SOURCE


Comparison of Small Gap vs. Standard Stripline BPM





SCDU Noise Floor Results











S Band Down Converter for LEUTL BPMs (buttons & striplines)

